


序号	报告编号	发布日期	结论	影像资料
35	GX-B1499/23-4-24090	2025. 1. 8	所检项目合格	
36	GX-B1499/23-4-24091	2025. 1. 8	所检项目合格	
37	GX-B1328/20-4-24172	2025. 1. 13	本次共检验电器 3支，3支验电器所检 项目合格。	


38	GX-B1328/20-4-24173	2025. 1. 13	本次共检短路接地线 3套，3套短路接地线 所检项目合格。	
39	GX-B1328/20-4-24174	2025. 1. 13	所检项目合格。	
40	GX-B1328/20-4-24167	2025. 1. 13	本次共检验电器158 支，158支所检项目 合格。	

41	GX-B1328/20-4-24168	2025. 1. 13	本次共检短路接地线140套，140套所检项目合格。	
42	GX-B1451/20-4-24184	2025. 1. 13	所检项目合格。	
43	GX-B1598/21-4-24027	2025/1/15	实测钢丝绳有效截面积损失百分比最大为2.21%，小于5%为正常。	

44	GX-B1598/21-4-24028	2025/1/15	实测钢丝绳有效截面积损失百分比最大为1.96%，小于5%为正常。		
45	GX-B1328/20-4-24170	2025/1/15	本次共检验电器5支，5支所检项目合格。		
46	GX-B1328/20-4-24171	2025/1/15	本次共检便携式短路接地线5组，5组所检项目合格。		

47	GX-B1547/20-4-24043~24059	2025/1/15	本次共共检继电保护装置17台，17台所检项目合格。	
48	GX-B1309/21-4-24006	2025. 1. 16	所检项目合格。	
49	GX-B1500/21-4-24025	2025. 1. 16	综合判定：合格。	

50	GX-B1500/21-4-24026	2025. 1. 16	综合判定：合格。	
51	GX-B1500/21-4-24027	2025. 1. 16	综合判定：合格。	
52	GX-B1328/20-4-25001	2025/1/16	本次共检验电器 9支，9支所检项目合格。	

53	GX-B1328/20-4-25002	2025/1/16	本次共检携带式短路接地线14组，14组所检项目合格。	
54	GX-B1310/21-4-24232	2025/1/16	符合标准要求。	
55	GX-B1310/21-4-24233	2025/1/16	符合标准要求。	

56	GX-B1310/21-4-24234	2025/1/16	符合标准要求。		
57	GX-B1416/22-4-24020	2025. 1. 16	综合判定：合格		
58	GX-B1416/22-4-24021	2025. 1. 16	综合判定：合格		

59	GX-B1416/22-4-24022	2025. 1. 16	综合判定：合格	
60	GX-B1310/21-4-25001	2025. 1. 16	符合标准要求。	  